



NOTE:
 PATCH SHALL MATCH EXISTING PAVEMENT AND BASE COURSE THICKNESSES, BUT NOT LESS THAN 3" HOT MIX ASPHALT (HMA) AND 6" AGGREGATE BASE COURSE (A.B.C.). COMPACT BASE COURSE TO 95% AASHTO T-180. COMPACT ASPHALT FROM 92% TO 96% OF MAXIMUM THEORETICAL DENSITY CP51. HMA SHALL CONFORM TO SECTION 401 OF THE STANDARD SPECIFICATIONS FOR ROAD AND BRIDGE CONSTRUCTION. PATCHES THAT ARE 6' WIDE OR GREATER SHALL BE PAVED WITH AN ASPHALT PAVING MACHINE. SEE SUBSECTION 401.04.14 OF THE STANDARD SPECIFICATIONS FOR ROAD AND BRIDGE CONSTRUCTION FOR PATCHING SPECIFICATIONS.

ASPHALT PATCH ADJACENT TO CURB AND GUTTER

DEPARTMENT OF PUBLIC WORKS AND UTILITIES
 ENGINEERING AND TECHNICAL SERVICES DIVISIONS
 CITY OF GRAND JUNCTION, COLORADO

STANDARD CONCRETE
 DETAIL

APPROVED: DN
 REVISED: FEB. 2007
 DRAWN: TLT

PAGE
 C-27